

C-35 Point 6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001


No.F6/DFS/MS/School/NDZ/2024/ 1032

Dated: 18/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Anglo Sanskrit V. J. Senior Secondary School, Darya Ganj New Delhi-02**, comprised of three blocks: **Main building** (Ground plus one upper floor), **Science Block** (Ground plus one upper floor) & **New Block** (Ground plus one upper floor) was granted Fire Safety Certificate by this department vide letter No.- F6/DFS/MS/School/NDZ/2020/515 dated 25.11.2020. The school building was re-inspected by the officer concerned of this department on 07.10.2024 in the presence of Mr. Gulshan Batra (H.O.S.) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010. The School building having three blocks **Main building** (Ground plus one upper floor), **Science Block** (Ground plus one upper floor) & **New Block** (Ground plus one upper floor) is fit for occupancy (**Group-B**) "**Educational Building**" with effect from18/10/2024.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.....18/10/2024.....at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
Tel:-011-23414000

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal,
Anglo Sanskrit V.J. Sr. Secondary School, Daryaganj, New Delhi-02.

Conditions for the validity of fire safety certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

Scanned with CamScanner
In-charge
A.S. M. Sr. Sec. ...
Da. ... New Delhi-2